

Columbia Water Company
220 Locust Street
Columbia, PA 17512
717-684-2188
Columbiawaterco.com

Title: RESIDENTIAL METER PIT FOR 5/8", 3/4" & 1" METERS - DETAIL

Date: 1/11/2023

Checked By: D. ZEAMER

Drawn By: T. KEYSER

Scale: NOT TO SCALE

Checked By: T. STIFFEY


Sheet No.: 1 OF 2

GENERAL NOTES:

- 1. METER AND I.P. SPUDS ARE PROVIDED BY COLUMBIA WATER COMPANY.
- 2. A PRESSURE REDUCING VALVE (PRV) SHALL BE INSTALLED BEFORE THE METER IF THE PRESSURE IS GREATER THAN 80 PSI. THE PRV SHALL BE FURNISHED AND INSTALLED BY THE CUSTOMER.
- 3. A DUAL CHECK VALVE MUST BE SUPPLIED AND INSTALLED AFTER THE METER BUT BEFORE THE 2ND SHUT OFF VALVE.
- 4. FULL SHUT-OFF VALVES (BALL VALVES) SHALL BE INSTALLED BEFORE AND AFTER ALL EQUIPMENT. (BOCA CODE P1506.1.2 & P1506.1.3)
- 5. THE METER/BACKFLOW ASSEMBLY MUST BE 15" OR LESS FROM METER PIT LID TO ALLOW FOR SERVICE/CHANGE OF WATER METER.
- 6. PRO-PRESS IS ACCEPTABLE IF PRESSURE IS BELOW 80 PSI.
- 7. METER PIT MUST BE WITHIN 5' OF THE COLUMBIA WATER COMPANY CURB STOP UNLESS CONDITIONS DO NOT PERMIT.

SPECIAL NOTES:

- 1. ANY CHANGES TO THESE REQUIREMENTS MUST BE APPROVED BY THE COLUMBIA WATER COMPANY.

 <p>Columbia Water Company 220 Locust Street Columbia, PA 17512 717-684-2188 Columbiawaterco.com</p>	Title: RESIDENTIAL METER PIT FOR 5/8", 3/4" & 1" METERS - DETAIL		
	Date: 1/11/2023	Checked By: D. ZEAMER	Drawn By: T. KEYSER
	Scale: NOT TO SCALE	Checked By: T. STIFFEY	Sheet No.: 2 OF 2